

OFFICE USE ONLY  
 Log No. 26910  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 2041

**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

1. OWNER Scott Reynolds ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Las Vegas Nevada

2. LOCATION SE 1/4 SW 1/4 Sec 17 T. 21 S. N/S R. 54 E Nye County \_\_\_\_\_

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	6	6
Gray Clay		6	14	8
Sandy Clay		14	38	24
Clay With Small Gravel		38	68	30
Soft Sandy Clay	x	68	82	14
Shale		82	90	8
Sandy Clay	x	90	136	46
Shale		136	141	5
Sandy Clay	x	141	160	19

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 160 feet  
 Casing record 160 ft. of 8 in. casing  
 Weight per foot 15 lbs. Thickness 156  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>160</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 160 feet  
 Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/2 in width 8 in long  
 From 80 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 SEP 30 1985  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started August 21, 1985  
 Date completed August 21, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 gals Draw down 4 feet 1/4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 58 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address St. Rt. Box 36525 Contractor  
 Nevada contractor's license number 7484  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 725 Actual Driller  
 Signed Charles Nyberg Contractor  
 Date September 20, 1985