WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26919
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2173

1. OWNER Robert Braswell
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 18 T. 21S N/S R. 54 E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Blk A Lot 14 Subdivision Name Charlotta Estates

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Clay | | 0 | 32 | 32 |
| Calichie | | 32 | 36 | 4 |
| Brown Clay | | 36 | 78 | 42 |
| Calichie | WB. | 78 | 85 | 7 |
| Brown Clay | | 85 | 117 | 32 |
| Calichie | WB. | 117 | 123 | 6 |
| Clay | | 123 | 143 | 20 |
| Calichie | WB | 143 | 148 | 5 |
| Clay | | 148 | 156 | 8 |
| Calichie | WB | 156 | 160 | 4 |

RECEIVED
NOV 26 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-2 85
Date completed 10 5 85

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 160 feet
Casing record 8 5/8 X 160
Weight per foot 14.11 Thickness 156

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | 0 feet | 160 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation torch
Size perforation 1/8 Inch by 6 inch
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 48 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Custom Drilling Inc. (Contractor)
Address 4425 Stacy Ave. (Contractor)
Nevada contractor's license number 19219
Nevada contractor's drillers number 1081
Nevada driller's license number 1426 (Actual Driller)
Signed C. B. Capshaw (Contractor)
Date 10-10 85

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY O-627 CR434