WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26922
Permit No.
Basin 162

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2289

1. OWNER Ernest Montoya
MAILING ADDRESS 3815 Nellis Blvd. LV NV.
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 20 T. 21S N/S R. 54 E Nye County
PERMIT NO. (Issued by Water Resources) Lot 124 (Parcel No.) Green Saddle Ranch (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	15	15
Calichie		15	21	6
Sandy Clay		21	29	8
Clay		29	38	9
Calichie		38	42	4
Clay		42	74	32
Calichie	WB	74	82	8
Clay		82	115	33
Calichie	WB	115	122	7
Clay		122	140	18
Calichie	WB	140	146	6
Clay		146	160	14

RECEIVED
JAN 13 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-4, 1985
Date completed 12-6, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 160 feet
Casing record 161 Ft. 8 5/8 inch
Weight per foot 14.11 Thickness .156

Diameter	From	To
8 5/8 inches	-1 feet	160 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch
Size perforation 1/8 inch by 6 inch
From -1 feet to 160 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 62 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cool °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Custom Drilling Inc (Contractor)
Address 4455 Stacey Ave L.V. NV (Contractor)
Nevada contractor's license number 19219
Nevada contractor's drillers number
Nevada driller's license number 1426 (Actual Driller)
Signed [signature] (Contractor)
Date 1-2-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434