



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1972

PRINT OR TYPE ONLY

OWNER EDWARD DickMAN ADDRESS AT WELL LOCATION LAS VEGAS
 MAILING ADDRESS Box 348 HSR 70 SUN CLUB, STATE LINE Rd. NORTH
JEAN NEVADA 89019

2. LOCATION NW 1/4 SW 1/4 Sec. 15 T. 24 M/S R. 56 E County _____

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

| | | |
|---|--|---|
| 3. TYPE OF WORK | 4. PROPOSED USE | 5. TYPE WELL |
| New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> | Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> | Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> |
| Deepen <input type="checkbox"/> Other <input type="checkbox"/> | Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/> | Other <input type="checkbox"/> |

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------|--------------|------|-----|------------|
| SANDY TOP SOIL | | 0 | 3 | 3 |
| ROCK & SAND | | 3 | 9 | 6 |
| CORAL CONS | | 9 | 18 | 9 |
| ROCK & SAND | | 18 | 48 | 30 |
| SANDY CLAY | | 48 | 57 | 9 |
| LOOSE ROCK | WTR | 57 | 59 | 2 |
| CORAL CONS | | 59 | 82 | 23 |
| BROWN CLAY | | 82 | 105 | 23 |
| CEMENTED ROCK CONS | | 105 | 117 | 12 |
| GRAVEL & ROCK | WTR | 117 | 126 | 9 |
| CLAY CONS | | 126 | 152 | 26 |
| SANDY CLAY | | 152 | 168 | 16 |
| GRAVEL & ROCK | WTR | 168 | 175 | 7 |

8. WELL CONSTRUCTION

Diameter hole 14 inches Total depth 175 feet
 Casing record _____
 Weight per foot _____ Thickness 156
 Diameter 8 7/8 inches From 0 feet To 175 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 175 feet

Perforations:
 Type perforation FLAME CUT
 Size perforation _____
 From 145 feet to 175 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 59 feet below land surface
 Flow 0 G.P.M. 0 P.S.I.
 Water temperature 70 ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name R C B B INC. Contractor
 Address 1701 W CHARLSTON LAS VEGAS NEV Contractor
 Nevada contractor's license number 020301
 Nevada contractor's drillers number 564
 Nevada driller's license number 1352
 Signed Robert Spurbet Actual Driller
 Date March 3 - 86

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

RECEIVED
 MAR 5 1986
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 1-22-86 1986
 Date completed 3-2-86 1986