

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. _____

1. OWNER Herbert B. Williams ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4182 Walnut Blvd
Walnut Creek, Calif 94596
 2. LOCATION NW 1/4 NW 1/4 Sec 25 T. 40 N. R. 64 E Elko County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay + rock chip	NO	0	19	19
Grey clay	"	19	24	5
Brown clay + rocks	90-95	24	114	90
Grey Sandy clay +				
Fine gravel	NO	114	119	5
Black rocks + grey clay	NO	119	139	20
Black rocks + brown clay	NO	139	150	11
Black rocks + grey				
brown clay	?	150	175	25

8. WELL CONSTRUCTION
 Drilled 8" 0-50 Drilled 16" 50-175
 Diameter hole 6 inches Total depth 175 feet
 Casing record 177' 6 7/8 O.D.
 Weight per foot 17 Thickness 250
 Diameter From To
6 inches + 2 feet 175 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Torch cut
 Size perforation 1/4 x 4"
 From 9.0 feet to 100 feet
 From 15.5 feet to 175 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 25 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality good

Date started 5 NOV 1985
 Date completed 11 NOV 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Boley + Henry Contractor
 Address Rt 1 Muntauk, Idaho 83344 Contractor
 Nevada contractor's license number 4641 A
 Nevada contractor's drillers number 517
 Nevada driller's license number 517 Actual Driller
 Signed B. Boley Contractor
 Date 15 Nov 1985

BAILER TEST
 G.P.M. 2 Draw down 70 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours