

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 436a

OWNER Marion Tripp ADDRESS AT WELL LOCATION Pilot Valley, Nev
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 11 T. 37 N. R. 69 E E1K0 County Meadow Valley Estates
 PERMIT NO. 135 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	9	9
Clay sand		9	19	21
Clay sand gravel		19	32	13
Clay sand		32	80	48
Pea gravel		80	87	7
Clay sand		87	120	33
Clay gravel sand		120	145	25
gravel sand	X	145	150	5
Clay sand gravel		150	174	24
Pea Gravel		174	180	6
Clay		180	185	5

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 185 feet
 Casing record _____
 Weight per foot _____ Thickness 0.156

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>185</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 50 feet feet
 Gravel packed: Yes No
 Gravel packed from 185 feet to 50 feet
 Perforations:
 Type perforation factory
 Size perforation 1/8 x 4 inches
 From 85 feet to 185 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 33 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality Good

Date started 12-18 1984
 Date completed 12-20 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name AAA Drilling Contractor
 Address Box 470 Paraca Nev Contractor
 Nevada contractor's license number 20684
 Nevada contractor's drillers number 904
 Nevada driller's license number 1438 Actual Driller
 Signed C.M. Robinson Jr. & Shano Bennett Contractor
 Date 1-14-85

BAILER TEST
 G.P.M. 25 Draw down 25 feet 1 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours