WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26994
Permit No.
Basin

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2102

OWNER Keith Whipple
MAILING ADDRESS Hiko NV 89001
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 14 T. 4 S N/S R. 60 E Lincoln County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: Replacement well, approx. 50' S
New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☒ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel		0	52	52
Brown Clay		52	69	17
Hard pan, Cemented gravel		69	72	3
Sand & gravel		72	95	23
Coarse gravel		95	110	15
Layers, sand, gravel		110	164	54
cemented gravel & clay		164	166	2
Clay		166	193	27

RECEIVED
MAR 25 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Jan. 25, 1986
Date completed Mar. 19, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	300	50'	24 hours

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 16" to 110' 12" to 110 to 193' inches Total depth 193 feet
Casing record 12" 0 to 163 ⅜" wall
~~Weight per foot~~ 8" 163 to 193' Thickness .188 wall

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50' feet to 160' feet

Perforations:
Type perforation Torch
Size perforation ¼ X 12
From 56 feet to 193 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 71 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Darell H. Free (Contractor)
Address Box 122 Panaca, NV (Contractor)
Nevada contractor's license number 3422
Nevada contractor's drillers number 30
Wayne Lister
Nevada driller's license number 1441 (Actual Driller)
Signed Darell H. Free (Contractor)
Date 3/19/86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434