WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 27002
Permit No.
Basin 212

inhook

NOTICE OF INTENT NO. 2130

PRINT OR TYPE ONLY

1. OWNER Franis LEE ELEIS
MAILING ADDRESS LEE OASIS SR#38 box #1

ADDRESS AT WELL LOCATION ½ mil, past CHARLESTON
TURN OFF ON RANCHO HIGH WAY

2. LOCATION n½ ¼ ne ¼ Sec. 1 T. 19 N/S R. 59 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well XXXXXXX Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐XX Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐XXXXXX
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CEMENT | | | | |
| LIME STONE | | 0 | 528 | 528 |
| FRIST H20 | | 470 | | |
| 10gpm | | | | |
| MAIN H20 | | 528 | | |
| 65gpm | | | | |

RECEIVED
SEP 3 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-16, 19 85
Date completed 8-22, 19 85

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 528 feet
Casing record 8&5-8
Weight per foot 14.6 Thickness 156

| Diameter | From | To |
|---|---|---|
| 8&5-8 inches | 0 feet | 528 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes XXXXX No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☐XXXXXXXX
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation TORCH
Size perforation 3 per ft
From 528 feet to 488 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 410 feet below land surface
Flow 65 G.P.M. 0 P.S.I.
Water temperature 67 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name VEGAS DRILLING CO, (Contractor)
Address 5956 calvert, LasVegas NV. 89130 (Contractor)
Nevada contractor's license number 015972
Nevada contractor's drillers number 944
Nevada driller's license number 944 (Actual Driller)
Signed Bruce Robinson (Contractor)
Date 8-19-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434