



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 2139

PRINT OR TYPE ONLY

OWNER MR AND MRS. MULDR ADDRESS AT WELL LOCATION Off. NO. THOM
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SE 1/4 Sec. 12 T. 19 N/S R. 60 E CLARK County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK	New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	4. PROPOSED USE	Irrigation <input type="checkbox"/>	Test <input type="checkbox"/>	5. TYPE WELL	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
	Deepen <input type="checkbox"/>	Other <input type="checkbox"/>		Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>		Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY AND GRAVEL		0	200	200
CEMENT GRAVEL		200	210	10
CLAY		210	250	40
CEMENT LIME STONE		250	280	30
CLAY AND GRAVEL		280	400	120
FRIST WATER STRATA	196			
MAIN WATER STRATA	360			

8. WELL CONSTRUCTION

Diameter hole 12 1/2 inches Total depth 400 feet
 Casing record 8&5/8
 Weight per foot 11.56 Thickness 1.56

Diameter	From	To
<u>8&5/8</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
 Depth of seal 200 feet
 Gravel packed: Yes No
 Gravel packed from 400 feet to 200 feet

Perforations:
 Type perforation TORCH
 Size perforation 6 PER FOOT

From	To
<u>400</u> feet	<u>360</u> feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

RECEIVED

NOV 6 1985

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started XXXX 10-16, 1985
 Date completed 10-21, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AIR ~~RAISER~~ TEST

G.P.M. 120 Draw down 188 feet 3 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 80 feet below land surface
 Flow 120 G.P.M. 0 P.S.I.
 Water temperature 69 °F. Quality GOOD

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VEGAS DRILLING CO. Contractor
 Address 5956 CALVERT LAS VEGAS NV. 89130 Contractor
 Nevada contractor's license number 015972
 Nevada contractor's drillers number 944
 Nevada driller's license number 944 Actual Driller

Signed [Signature] Contractor
 Date 11-4-85