WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27106
Permit No. 47003
Basin

PRINT OR TYPE ONLY

OWNER Al Garrison Water ~~Dan Gibson~~ Users Assn.
MAILING ADDRESS 4115 Al Garrison #54691
ADDRESS AT WELL LOCATION
NOTICE OF INTENT NO. 1295

2. LOCATION SW ¼ SW ¼ Sec. 4 T. 20 N/S R. 60 E. Clark County
PERMIT NO. 47003 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand Rocks | | 0 | 5 | 5 |
| Caliche | | 5 | 22 | 17 |
| Clay | | 22 | 198 | 176 |
| Cmt Gravel | | 198 | 332 | 134 |
| Cmt Gravel w/ Streak of Clay | | 332 | 450 | 118 |

RECEIVED
OCT 10 1983
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started 8-4-, 19 83
Date completed 8-5-, 19 83

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10¼ inches Total depth 450 feet
Casing record 0-450
Weight per foot ..... Thickness .156

| Diameter | From | To |
|---|---|---|
| 6 5/8 inches | 0 feet | 450 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☑ No ☐ Type Cmt
Depth of seal 50 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 450 feet

Perforations:
Type perforation Factory
Size perforation 5/32
From 390 feet to 450 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 346 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lee R. Thomas (Contractor)
Address 5965 N. Maverick (Contractor)
Nevada contractor's license number 10331
Nevada contractor's drillers number 623
Nevada driller's license number 623 (Actual Driller)
Signed Lee R. Thomas (Contractor)
Date 10-6-83

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY

O-627 CR434