WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

CORRECTED

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27171
Permit No.
Basin

NOTICE OF INTENT NO. 0456

1. OWNER Jack Breslin
MAILING ADDRESS 1336 So. Decatur Blvd
ADDRESS AT WELL LOCATION Cimmaron & O'Bannon

2. LOCATION NW ¼ SE ¼ Sec. 4 T. 21S N/S R. 60 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sandy gravel		0	3	3
cemented conglomerate		3	14	11
red sandstone		14	16	2
cemented conglomerate		16	305	289
gray lime		305	319	14
cemented conglomerate w/ streeks of lime		319	480	161
loose pea gravel	X	480	483	3
fractured cemented conglomerate	X	483	760	277

RECEIVED
MAR 6 1985
Div. of Water Resources
Branch Office • Las Vegas, NV

Date started March 16, 19 84
Date completed March 22, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air	38	?	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 760 feet
Casing record 6-5/8
Weight per foot 10.78 Thickness .156

Diameter	From	To
6-5/8 inches	0 feet	760 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 4 x 4 around
From 580 feet to 760 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 596 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Nevada contractor's license number 018917
Nevada contractor's drillers number 1301
Nevada driller's license number 1376 (Actual Driller)
Signed [signature] (Contractor)
Date March 5, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27171
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6456

1. OWNER Jack Breslin
MAILING ADDRESS 1336 So. Decatur Blvd.
ADDRESS AT WELL LOCATION Cimmarron & O bannon

2. LOCATION NW ¼ SE ¼ Sec. 4 T. 21S N/S R. 60 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [XX] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [XX]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0	3	3
cemented conglom.		3	14	11
red sandstone		14	16	2
cemented congom		16	305	289
gray line		305	319	14
cemented conglom.				
w/ streeks of lime		319	480	161
loose pea gravel	X	480	483	3
fractured cemented				
conglomerate	X	483	760	277

RECEIVED
MAY 11 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started March 16, 19 84
Date completed March 22, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air	38	?	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 760' feet
Casing record 8-5/8"
Weight per foot 16.94 Thickness .156

Diameter	From	To
85/8 inches	0 feet	760 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50' feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 4 x 4 around
From 580 feet to 760 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 596 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. (Contractor)
Address 4847 So. Valley View (Contractor)
Nevada contractor's license number 018917
Nevada contractor's drillers number 1301
Nevada driller's license number 1376 (Actual Driller)
Signed [signature] (Contractor)
Date May 9, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434