WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27177
Permit No.
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1753

1. OWNER Richard K. Thompson
MAILING ADDRESS 3905 El Jardin
Las Vegas, Nev. 89102

ADDRESS AT WELL LOCATION 6120 Feldman
Las Vegas, Nev.

2. LOCATION NE ¼ SW ¼ Sec. 36 T. 21 ☒/S R. 60 E. Clark County
PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. *PROPOSED USE (See below)
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Cemented gravel | | 0 | 8 | 8 |
| Caliche | | 8 | 12 | 4 |
| Cemented gravel | | 12 | 460 | 448 |

*Non consumptive - for ground water heat pump use

RECEIVED
APR 19 1985
Div. of Water Resources
Branch Office: Las Vegas, NV

Date started October 17, 1984
Date completed ____, 19____

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 460 feet
Casing record
Weight per foot ____ Thickness .156

| Diameter | From | To |
|---|---|---|
| ~~*1~~ 6 5/8 inches | +1 feet | 460 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 460 feet

Perforations:
Type perforation None
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 280 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon Las Vegas, Nevada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number #856 (Griffiths) ~~XXXXXXXXXXXXXXXX~~ (Actual Driller)
Signed Richard K. Thompson (Contractor)
Date April 15, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434