WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PW 3

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

in book

OFFICE USE ONLY
Log No. 27180
Permit No. 16069
Basin

NOTICE OF INTENT NO. 1765

1. OWNER Tropicana Hotel
MAILING ADDRESS c/o The Mark Group
2300 Paseo del Prado Bldg. D-108, Las Vegas 89102

ADDRESS AT WELL LOCATION
Las Vegas Blvd. So. & Tropicana

2. LOCATION NW ¼ NW ¼ Sec. 28 T. 21 S/S R. 61 E. Clark County

PERMIT NO. 16069 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Commercial
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey soil		0	20	20
White clay		20	35	15
Red clay, gravel		35	55	20
Red sandy clay, gravel		55	175	120
White clay & gravel		175	195	20
Gravel & clay		195	395	200
Red clay, some gravel		395	515	120
White clay, some gravel		515	535	20
Brn. clay, gravel		535	555	20
Cemented gravel		555	615	60
Gravel & clay		615	755	140
Red sandy clay, sandstone		755	775	20
Gravel, clay, sand		775	795	20
Sandstone, clay, gravel		795	835	40
Clay, some gravel		835	845	10

RECEIVED
NOV 13 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started ~~August~~ Aug. 28, 19 85
Date completed Sept. 10, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth 845 feet
Casing record
Weight per foot ..... Thickness .3125

Diameter	From	To
12 inches	+1 feet	813 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 150 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 150 feet to 845 feet

Perforations:
Type perforation Screen
Size perforation .050 slot
From 297 feet to 317 feet
From 356 feet to 371 feet
From 555 feet to 619 feet
From 785 feet to 805 feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 102 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon Las Vegas, Nevada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number 856 (Griffiths) (Actual Driller)
Signed Richard K. Thompson (Contractor)
Date November 11, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434