


OFFICE USE ONLY
 Log No. 27181
 Permit No. 16070
 Basin _____



OBSERVATION WELL - AMENDED REPAIR WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1761

OWNER Tropicana Hotel ADDRESS AT WELL LOCATION Las Vegas Blvd. So. & Tropicana
 MAILING ADDRESS c/o The Mark Group 2300 Paseo del Prado Bldg. D-108, Las Vegas, Nevada 89102
 2. LOCATION NW 1/4 NW 1/4 Sec. 28 T. 21 N/S R. 61 E Clark County
 PERMIT NO. 16070 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clayey soil		0	20	20
White White clay		20	35	15
Red clay, gravel		35	55	20
Red sandy clay, gravel		55	175	120
White clay & gravel		175	195	20
Gravel & clay		195	395	200
Red clay, some gravel		395	515	120
White clay, some gravel		515	535	20
Brn. clay, gravel		535	555	20
Cemented gravel		555	615	60
Gravel & clay		615	755	140
Red sandy clay, sandstone		755	775	20
Gravel, clay, sand		775	795	20
Sandstone, clay, gravel		795	835	40
Clay, some gravel		835	845	10
Clay		845	900	55

8. WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 900 feet
 Casing record PVC Schedule 40
 Weight per foot _____ Thickness _____
 Diameter _____ From _____ To _____
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 900 feet

Perforations:
 Type perforation Saw cut
 Size perforation 1/8" x 2 1/2"
 From 240 feet to 260 feet
 From 295 feet to 315 feet
 From 555 feet to 615 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
 JUN 12 1986
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started May 31, 19 85
 Date completed June 14, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL
 Static water level 100 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC.
4185 West Harmon
 Address Las Vegas, Nevada 89103
 Contractor
 Nevada contractor's license number 4286A
 Nevada contractor's drillers number 582
 Nevada driller's license number 856 (Griffiths)
 Actual Driller
 Signed Richard K. Thompson
 Contractor
 Date (Amended 6/10/86)

