WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27182
Permit No. 16070
Basin

PW-4 AMENDED REPORT
PRINT OR TYPE ONLY

NOTICE OF INTENT NO. ~~xxxx~~ 2246

OWNER Tropicana Hotel
MAILING ADDRESS c/o The Mark Group
2300 Paseo del Prado Bldg. D-108, Las Vegas, Nevada 89102

ADDRESS AT WELL LOCATION
Las Vegas Blvd. & Tropicana

2. LOCATION NW ¼ NW ¼ Sec. 28 T. 21 ~~N~~/S R. 61 E Clark County

PERMIT NO. 16070 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. COMMERCIAL PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey soil		0	38	38
White clay, some gravel		38	49	11
Red clay, some gravel		49	128	79
Brrown clay		128	153	25
Sand & gravel		153	250	97
Sand, gravel, clay		250	310	60
Gravel, red clay		310	348	38
Red clay		348	480	132
Brn. sandy clay, gravel		480	548	68
Cem. sand & gravel		548	588	40
Gravel		588	602	14
Clay & gravel		602	610	8

RECEIVED
JUN 12 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started October 11, 19 85
Date completed October 21, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth 610 feet
Casing record
Weight per foot Thickness .3125

Diameter	From	To
12 3/4 inches	+2 feet	610 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 150 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 150 feet to 610 feet

Perforations:
Type perforation Screen
Size perforation .050 slot
From 300 feet to 305 feet
From 350 feet to 370 feet
From 530 feet to 600 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 100 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon Las Vegas, Nevada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number 856 (Griffiths) (Actual Driller)
Signed Richard K. Thompson (Contractor)
Date (Amended 6/10/86)

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PW 4

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27182
Permit No. 16070
Basin

NOTICE OF INTENT NO. 2246

1. OWNER Tropicana Hotel
MAILING ADDRESS c/o The Mark Group
2300 Paseo del Prado Bldg. D-108, Las Vegas

ADDRESS AT WELL LOCATION
Las Vegas Blvd. So. & Tropicana
89102

2. LOCATION NW ¼ NW ¼ Sec. 28 T. 21 S R. 61 E Clark County

PERMIT NO. 16070 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Commercial
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey soil		0	38	38
White clay, some gravel		38	49	11
Red clay, some gravel		49	128	79
Brown clay		128	153	25
Sand & gravel		153	250	97
Sand, gravel, clay		250	310	60
Gravel, red clay		310	348	38
Red clay		348	480	132
Brn. sandy clay, gravel		480	548	68
Cem. sand & gravel		548	588	40
Gravel		588	602	14
Clay & gravel		602	610	8

RECEIVED
NOV 13 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started October 11, 1985
Date completed October 21, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 17½ inches Total depth 610 feet
Casing record
Weight per foot Thickness .3125

Diameter	From	To
12 3/4 inches	+2 feet	610 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 150 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 150 feet to 610 feet

Perforations:
Type perforation Screen
Size perforation .030 slot
From 300 feet to 305 feet
From 350 feet to 370 feet
From 530 feet to 600 feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 100 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon, Las Vegas, Nevada 89103 (Contractor)
Nevada contractor's license number 4286A
Nevada contractor's drillers number 582
Nevada driller's license number 856 (Griffiths) (Actual Driller)
Signed Richard K. Thompson (Contractor)
Date November 11, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434