WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 27204
Permit No. 24053
Basin

1. OWNER Clark County Parks
MAILING ADDRESS
ADDRESS AT WELL LOCATION
NOTICE OF INTENT NO. 1260

2. LOCATION NW ¼ SW ¼ Sec. 1 T. 22S N/S R. 61 E. Clark County
PERMIT NO. 24053 Issued by Water Resources
Parcel No.
Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
silty sand		0	18	18
clay & gravel		18	40	22
pea gravel	x	40	44	4
(water cemented off)				
brown clay & gravel		44	65	21
pea gravel	xx	65	70	5
brn clay & gravel		70	120	50
brn sandy clay		120	175	55
course gravel	xx	175	183	8
brn chunky clay		183	220	37
hard lava rock		220	270	50
coarse gravel	XX	270	280	10
cemented conglom.		280	300	20
brn streaky clay		300	320	20
brn clay		320	390	70

RECEIVED
DEC 10 1984
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-5, 19 84
Date completed 7-5, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1800	800-900		8 hrs

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 18 inches Total depth 390 feet
Casing record 12-3/4
Weight per foot 33-38lb ft. Thickness .250

Diameter	From	To
20 inches	0 feet	50 feet
12-3/4 inches	0 feet	390 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 390 feet

Perforations:
Type perforation machines
Size perforation 1/8 x 2½ long 10 around
From 40 feet to 80 feet
From 160 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 42 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. Contractor
Address 4847 So. Valley View Contractor
Nevada contractor's license number 018917
Nevada contractor's drillers number 1301
Nevada driller's license number 1308 Actual Driller
Signed [signature] Contractor
Date December 06, 1984

(Rev. 6-81)
USE ADDITIONAL SHEETS IF NECESSARY
O-627 CR434