WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27274
Permit No.
Basin 228

1. OWNER George E. Youngkans ADDRESS P.O. Box 833 Beatty Nev

2. LOCATION S.W. ¼ S.E. ¼ Sec. 33 T. 10S N/S R. 47 E. Nye County
PERMIT NO. Parcel # 18-091-03 - well # 2

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand & Gravel		0	20'	20'
Black Sand	20	20'	30'	10'
Brown Sand & Gravel		30'	52'	22'
Sand & Gravel		52'	78'	26'
Clay		78'	80'	2'
Gravel		80	87'	7'

RECEIVED
OCT 25 1984
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 9-28-84, 19
Date completed 10-4-84, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
No pump Test Run			

BAILER TEST
G.P.M. 30 Draw down 2 feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼" inches Total depth 87' feet
Casing record Set Casing @ 87'
Weight per foot 15# Thickness .188

Diameter	From	To
8" inches	-1' feet	87' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 87' feet to 50' feet

Perforations:
Type perforation ⅛" X 3"
Size perforation
From 67' feet to 87' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 20' Feet below land surface 20'
Flow G.P.M.
Water temperature Cool ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jack Sullivan
Address P.O. Box #881 Beatty Nev
Nevada contractor's license number 22059
Nevada driller's license number 1312
Signed J.R. Sullivan
Date 10-10-84

USE ADDITIONAL SHEETS IF NECESSARY

O-627