WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 27283
Permit No.
Basin

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 1950

OWNER Mike Butler
MAILING ADDRESS P.O. Box 267
Indian Springs NV 89018

ADDRESS AT WELL LOCATION Crystal
Nevada

2. LOCATION NW ¼ SW ¼ Sec. 8 T. 17 N/S R. 52 E NYE County
PERMIT NO. (Issued by Water Resources) Lot 10 Blk 5 (Parcel No.) Forty Acre Estates (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	5	5
Clay		5	8	3
Sandy Clay		8	25	17
Cemented Conglomerate		25	27	2
Sand & gravel		27	36	9
Gravel	WB	36	40	4
Sandy Clay	WB	40	48	8
Sand & gravel	WB	48	60	12
Sandy Clay	WB	60	66	6
Cemented gravel & sand		66	120	54
Sand & gravel	WB	120	130	10
Cemented Sand & gravel		130	135	5

RECEIVED
FEB 4 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-26, 1984
Date completed 10-29, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 135 feet
Casing record 136' 8" Casing
Weight per foot 14 lb. Thickness .156

Diameter	From	To
8 inches	-1 feet	135 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 135 feet

Perforations:
Type perforation Metal Saw
Size perforation 3 inch by 1/8 inch
From 91 feet to 135 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow Cool G.P.M. P.S.I.
Water temperature ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Steven G Hamrick (Contractor)
Address 3312 Thom Blvd. LV NV 89130 (Contractor)
Nevada contractor's license number 0022055
Nevada contractor's drillers number
Nevada driller's license number 1426
Signed Steven G. Hamrick (Actual Driller / Contractor)
Date 10-25-84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434