WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27281
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1051

OWNER Verne Gilliland.
MAILING ADDRESS Star Rt 15 Box 552C
Amargosa Valley
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 17S N/S R. 49 E. Nye County
PERMIT NO. (Issued by Water Resources) Lot 2 (Parcel No.) Martinson Subdivision (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand.		0	2	2
Sand & gravel		2	37	35
Caliche		37	39	2
Sand & gravel		39	74	35
Lime stone		74	76	2
Fine Sand		76	80	4
Sand & gravel		80	120	40
Sandy Clay		120	125	5
Cemented Sand & gravel		125	127	2
Sand & gravel		127	153	26
Cemented Sand & gravel		153	156	3
gravel		156	164	8

RECEIVED
FEB 4 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-8, 1984
Date completed 11-11, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 164 feet
Casing record 165 ft. 8 inch.
Weight per foot 14 lb. Thickness .156

Diameter	From	To
8 inches	-1 feet	164 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 164 feet

Perforations:
Type perforation Metal Saw.
Size perforation 1/8 inch by 3 inch
From 120 feet to 164 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 76 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Steven G Hamnick (Contractor)
Address 3312 Thom Blvd. LV NV 89130 (Contractor)
Nevada contractor's license number 0022059
Nevada contractor's drillers number
Nevada driller's license number 1426
Signed Steven G. Hamnick (Actual Driller) (Contractor)
Date 11-12-84

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434