



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6486

PRINT OR TYPE ONLY

1. OWNER L/S Ranches ADDRESS AT WELL LOCATION 6500  
 MAILING ADDRESS Mantella, Nevada 1/2 East of Toona draw

2. LOCATION NW 1/4 NW 1/4 Sec. 32 T. 40 N/S R. 67 E 11/2 County

PERMIT NO. 49464 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Soil		0	3	
Yellow clay's gravel		3	43	
Black clay		43	50	
" gravel		50	55	
Black clay		55	71	
Black sandstone		71		
3" cylinder pump set at 63'				

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 77 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188  

Diameter	From	To
<u>6</u> inches	<u>71</u> feet	<u>77</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 77 feet  
 Perforations:  
 Type perforation Factory milled  
 Size perforation 3/8 x 3"  
 From 52 feet to 62 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 33 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 64 ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge  
 Name R.V. Reynolds Contractor  
 Address Wells, Nev. Contractor  
 Nevada contractor's license number 014410  
 Nevada contractor's drillers number 1390  
 Nevada driller's license number 1390 Actual Driller  
 Signed [Signature] Contractor  
 Date 5/21/86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 20 Draw down 5 feet 4 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours