

OFFICE USE ONLY
 Log No. 27345
 Permit No. _____
 Basin 7-92B

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7693

1. OWNER MARVIN MATSON ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 11695 Overland Rd. _____
Reno, NV 89506 _____
 2. LOCATION NE 1/4 SW 1/4 Sec. 15 T. 21 N/S R. 19 E. Washoe County
 PERMIT NO. _____ Parcel No. _____
 Issued by Water Resources _____ Subdivision Name Lemmon Valley

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1	1
Soft brown sand		1	17	16
brown sandy clay		17	66	49
Soft zone		66	68	2
Brown sandy clay		68	115	47
Soft fine brown sand		115	130	15
D.G.		130	135	5
Weathered granite		135	146	11
Small fracture (no water)		146	147	1
Weathered granite		147	169	22
Small Gray granite		169	194	25
Small fracture (no water)		194	195	1
Gray granite		195	215	20
Fracture	X	215	216	1
Gray granite		216	235	19
Fracture	X	235	236	1
Granite		236	243	7
Fracture	X	243	246	3
Gray granite		246	252	6

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 252 feet
 Casing record 252
 Weight per foot _____ Thickness 156

Diameter	From	To
<u>6 5/8"</u> inches	<u>0</u> feet	<u>200</u> feet
<u>5" liner</u> inches	<u>192</u> feet	<u>252</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 252 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6" around
 From 192 feet to 252 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 116 feet below land surface
 Flow 25 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality clear

Date started 6-25-86, 19____
 Date completed 6-26-86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Reno, NV 89510 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923 Actual Driller
 Signed Wayne Drilling, Inc. Contractor
 Date July 1, 1986

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours