

OFFICE USE ONLY
 Log No. 27350
 Permit No. _____
 Basin 6-885 (Rebocquada)

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 5136

1. OWNER Santiago Basterreche ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 15793 Fawn Lane
2175 W. Plumb Reno Nev. Reno Nev.
 2. LOCATION SW 1/4 SW 1/4 Sec. 36 T. 18 N/S R. 19 E Washoe County
 PERMIT NO. 150-241-06
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sandy Clay</u>		<u>0</u>	<u>20</u>	<u>20</u>
<u>Sand</u>		<u>20</u>	<u>80</u>	<u>60</u>
<u>Sand + Gravel</u>	<input checked="" type="checkbox"/>	<u>80</u>	<u>127</u>	<u>27</u>
<u>N 39.377047</u>				
<u>W 119.806106 NAD87</u>				
<u>Deepened under NDI 61971</u>				

8. WELL CONSTRUCTION
 Diameter hole 80 inches Total depth 127 feet
 Casing record 6 5/8
 Weight per foot 10 Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>127</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type Cement
 Depth of seal 5.5 feet
 Gravel packed: Yes No
 Gravel packed from 5.5 feet to 127 feet
 Perforations:
 Type perforation Factory
 Size perforation 3/32 x 3
 From 107 feet to 127 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Flow 0 G.P.M. 30 P.S.I.
 Water temperature Cold ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Sierra Pump & Drilling Contractor
 Address Carson City Contractor
 Nevada contractor's license number 0122360
 Nevada contractor's drillers number _____
 Nevada driller's license number 1001 Actual Driller
 Signed Susan R. Offenberg Contractor
 Date 4/21/86

Date started 4/17 1986
 Date completed 4/20 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Blown</u>	<u>30</u>	<u>0</u>	<u>3 Hr</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours