WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27365
Permit No.
Basin 6-83 Tracy Segment

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5953

1. OWNER Capriotti Const. Co.
MAILING ADDRESS 2995 Mill St. Reno Nev 89502
ADDRESS AT WELL LOCATION Lockwood across River.

2. LOCATION ¼ SW ¼ Sec. 16 T 19 N/S R. 21 E story County
PERMIT NO. W 183 (Issued by Water Resources) | Parcel No. | Lockwood Trailer Court (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Top Soil		0	3	
Boulder + brown clay		3	25	
Medium hard Black Volcanic Rock		25	200	
Hard Black Rock		200	210	
Broken Fracture Rock	210	210	221	
soft fractured volcanic rock		221	245	
Hard Black Rock		245	250	
Fracture Black Rock		250	265	
Hard Black Rock		265	273	
Fracture Black Rock		273	282	
Fracture Red Rock		282	286	
Fracture Green Rocks		286	291	
soft rocks & mixed colors		291	300	
Hard Black Rock		300	310	
soft black volcanic Rock		310	325	

Date started April 6, 1986
Date completed April 9, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 1/4 inches Total depth 325 feet
Casing record 325 ft
Weight per foot 19 Thickness 188

Diameter	From	To
8 5/8 inches	0 feet	218 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 100 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 100 feet to 325 feet

Perforations:
Type perforation Mill slot
Size perforation 3 x 1/8 - ~~double~~ triple
From 218 feet to 325 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 20 feet below land surface
Flow Approx 300 G.P.M. ..... P.S.I.
Water temperature cold ° F. Quality unknown

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams + Sons (Contractor)
Address 22 S. Patterson, Sparks, NV (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 1287 (Actual Driller)
Signed Paul E. Williams Sr. (Contractor)
Date 4-22-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434