

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7472

PRINT OR TYPE ONLY

1. OWNER Rodger Woolley ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1400 E. 9th. St. 10455 San Fernando Rd
Reno, Nv 89512 Silver Knolls

2. LOCATION NE 1/4 Sec 26 T 21 N/S R. 18 E Washoe County
 PERMIT NO. 81-363-20

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Clay		0	90	90
Blue Clay mixed with brown clay with white sand		90	138	48
T.D. 138				

8. 10"-60" WELL CONSTRUCTION
 Diameter hole 8 1/2 inches Total depth 138 feet
 Casing record 6 5/8 .156
 Weight per foot 10.70 Thickness .156

Diameter	From	To
<u>6 5/8</u> inches	<u>2</u> feet	<u>138</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 138 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 117 feet to 138 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Flow 25+ G.P.M. _____ P.S.I.
 Water temperature cool ° F. Quality _____

Date started 6/4/86, 19____
 Date completed 6/4/86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop			

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor

Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
 Actual Driller

Signed Roger M. Thrall
 Roger M. Thrall Contractor
 Date 6/4/86

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours