WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 27394
Permit No.
Basin 8-105 Carson V.

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 6142

1. OWNER Michael Minuck
MAILING ADDRESS GENOA, NEVADA
ADDRESS AT WELL LOCATION Logging Camp Road GENOA, NEVADA

2. LOCATION SW ¼ NE ¼ Sec. 9 T. 13 N/S R. 19 E Douglas County
PERMIT NO. ____ Issued by Water Resources | Parcel No. 3 | Subdivision Name GENOA ESTATES

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Highly fractured Talus rocks w/ Some Clay Seams		0	89	89
Broken grey Colored Granite		89	113	24
Hard Solid Granodiorite		113	119	6
Broken Glacial fill carrying large quantity of water	✓	119	145	26
T.D. = 145'				

Date started June 11, 1986
Date completed June 13, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to develop for 2 Hours			
Well capable of 30+ GPM			

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 11 to 6 inches Total depth 145 feet
Casing record 6 5/8"
Weight per foot ____ Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 66 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 66 feet to 145 feet

Perforations:
Type perforation Factory Cut
Size perforation 3/32 x 3 1/2
From 123 feet to 143 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 62 feet below land surface
Flow 30+ G.P.M. — P.S.I.
Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co. (Contractor)
Address P.O. Box 3432 Carson City, NV (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number ____
Nevada driller's license number 1450 (Actual Driller)
Signed [signature] (Contractor)
Date June 15, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434