

OFFICE USE ONLY
 Log No. 207376
 Permit No. _____
 Basin 10-137B Big Smoky V. North

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 1063

OWNER MVC Bennett ENT. Charles Bennett ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS Box 66 Round Mt. H. NV 89045 _____
 2. LOCATION NE 1/4 SW 1/4 Sec 4 T. 10 N 8 R. 43 E HYE County
 PERMIT NO. 2 Parcel No. _____ Subdivision Name Scenic Courts
 Issued by Water Resources

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	15	
Sandy clay		15	25	
Clay		25	35	
Sandy clay		35	42	
Clay		42	58	
gravel & Sand		58	82	
Clay		82	86	
gravel		86	103	
Clay		103	143	

8. WELL CONSTRUCTION
 Diameter hole 12 inches Total depth 14.3 feet
 Casing record 0 - 14.3
 Weight per foot _____ Thickness 1/4

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>14.3</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type _____
 Depth of seal 50 FT feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 14.3 feet
 Perforations:
 Type perforation slit
 Size perforation 1/8"
 From 50 feet to 85 feet
 From 87 feet to 107 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 16 feet below land surface
 Flow NO G.P.M. _____ P.S.I. _____
 Water temperature 43 °F. Quality good

Date started _____, 19____
 Date completed May 23, 86, 19____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Don Pollock Contractor
 Address P.O. 123 Ely, Nevada 89301 Contractor
 Nevada contractor's license number NO 018692 + 018693
 Nevada contractor's drillers number 871
 Nevada driller's license number 771 Actual Driller
 Signed Don Pollock Contractor
 Date June 16, 86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1200</u>	<u>35</u>	<u>NO</u>	<u>72</u>
_____	_____	_____	_____
_____	_____	_____	_____

Air Lift BAILER TEST
 G.P.M. 200 + Draw down _____ feet 5 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours