WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27402
Permit No.
Basin 88-

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6842

1. OWNER JOHN BROWN
MAILING ADDRESS 1042 Robert St.
Reno, NV 89502

ADDRESS AT WELL LOCATION
20957 Eaton Rd.
Pleasant Valley

2. LOCATION NE ¼ NE ¼ Sec. 7 T. 17 N/S R. 20 E Washoe County
PERMIT NO. ... Issued by Water Resources | Parcel No. | Pleasant Valley Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	2	2
Brown clay w/ gravels and sand		2	36	34
Soft zone		36	37	1
Brown clay		37	65	28
Layer of broken volcanic rock		65	70	5
Brown soft clay		70	95	25
Gray sandy clay		95	110	15
Soft zone	X	110	126	16
Cemented gravels and grayish sand		126	131	5
Soft zone	X	131	141	10
Cemented gray gravels and sand		141	150	9

Date started 6-10-86, 19
Date completed 6-10-86, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ... Draw down ... feet ... hours
G.P.M. ... Draw down ... feet ... hours
G.P.M. ... Draw down ... feet ... hours

8. WELL CONSTRUCTION
Diameter hole 10 x 6 inches Total depth 150 feet
Casing record 150 ft.
Weight per foot ... Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 2½ x 6" around
From 115 feet to 145 feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet
From ... feet to ... feet

9. WATER LEVEL
Static water level 40 feet below land surface
Flow 100+ G.P.M. ... P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, INC. (Contractor)
Address P.O. 12370 Reno, NV 89510 (Contractor)
Nevada contractor's license number 22549
Nevada contractor's drillers number 908
Nevada driller's license number 923 (Actual Driller)
Signed Gary C. Holman (Contractor)
Date June 13, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434