

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER Norman Binette ADDRESS AT WELL LOCATION off Greyvan Rd. Pyramid Hwy.
 MAILING ADDRESS 2382 Roundhouse Rd, Sparks, NV 89431

2. LOCATION SW 1/4 NW 1/4 Sec. 31 T. 23N N/S R. 21 E Washoe County
 PERMIT NO. 2605 Parcel No. 76-231-07 Subdivision Name Pyramid Valley Unit #5

3. TYPE OF WORK: New Well Recondition Deepen Other

4. PROPOSED USE: Domestic Irrigation Municipal Industrial Test Stock

5. TYPE WELL: Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	
Clay + gravel sand		3	90	
Gravel + sand	water	90	98	8
D.G. and gravel		98	120	
Brown Peat Gravel		120	162	

8. WELL CONSTRUCTION

Diameter hole 12" inches Total depth 162 feet
 Casing record 6 5/8
 Weight per foot 11.99 Thickness 168

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>53</u> feet
<u>6</u> inches	<u>50</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 162 feet

Perforations:
 Type perforation Factory
 Size perforation 3/32
 From 136 feet to 110 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 32 feet below land surface
 Flow No G.P.M. _____ P.S.I. _____
 Water temperature Cold ° F. Quality unknown

Date started 26 FEB 1986, 19____
 Date completed 7 March 1986, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name W. M. Blain Well Drilling Contractor
 Address Bx 353, Dayton, NV 89403 Contractor
 Nevada contractor's license number 10950
 Nevada contractor's drillers number 1118
 Nevada driller's license number 1436 Actual Driller

BAILER TEST

G.P.M. 10-15 Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

Signed W. M. Blain Contractor
 Date 3-7-86