

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. ....

PRINT OR TYPE ONLY

1. OWNER Joe Keys ADDRESS AT WELL LOCATION Hamlet, Nev.  
 MAILING ADDRESS P.O. #18  
Rena Nev.  
 2. LOCATION NE 1/4 NE 1/4 Sec. 29 T. 33 N. 57 E. 57 County  
 PERMIT NO. 43122  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                | Water Strata | From | To  | Thick-ness |
|-------------------------|--------------|------|-----|------------|
| Top Soil                |              | 0    | 5   | 5          |
| GRAVEL                  |              | 5    | 7   | 2          |
| BROWN CLAY              |              | 7    | 18  | 11         |
| Grey SAND               |              | 18   | 44  | 26         |
| CLAY                    |              | 44   | 47  | 3          |
| Grey SAND               |              | 47   | 87  | 40         |
| GRAVEL                  |              | 87   | 150 | 113        |
| CLAY                    |              | 150  | 190 | 40         |
| GRAVEL + SAND           |              | 190  | 247 | 57         |
| SANDY CLAY              |              | 247  | 255 | 8          |
| SOME WATER + SANDY CLAY |              | 255  | 308 | 53         |
| SAND + GRAVEL           |              | 308  | 348 | 40         |
| CLAY                    |              | 348  | 410 | 62         |

Well Filled With cement  
 casing drilled  
 No + enough water for irrigation

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 410 feet  
 Casing record 50  
 Weight per foot Thickness 250  
 Diameter 5/8 inches From 1 feet To 50 feet  
 Surface seal: Yes  No  Type cement  
 Depth of seal 0 - 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation \_\_\_\_\_  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 17' feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

Date started May 10, 1986  
 Date completed May 30, 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eising Drilling & Pump, Inc. Contractor  
 Address Box 919, Twin Falls, Idaho 83301 Contractor  
 Nevada contractor's license number 0017177  
 Nevada contractor's drillers number 1295  
 Nevada driller's license number 945 Actual Driller  
 Signed Arnold Eising Contractor  
 Date May 30, 1986

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours