WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27439
Permit No. 49790
Basin 6-91 Truckee Canyon Seg.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4762

1. OWNER Washoe Co. School Dist.
MAILING ADDRESS 425 East Ninth St. Reno, Nev. 89520
ADDRESS AT WELL LOCATION 309 Bridge St Verdi, Nev.

2. LOCATION SW ¼ SW ¼ Sec. 8 T. 19 N/S R. 18 E. Washoe County
PERMIT NO. 49790 (Issued by Water Resources) 38-060-04 (Parcel No.) Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☑ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders w/ Clay Binder		0	10	10
Brown Clay		10	24	14
grey clay w/gravel		24	60	36
grey clay w/ sand		60	150	90
grey clay (Hard)		150	195	45
grey shale		195	230	35
lignite layers		230	300	70
shale (rough)	✓	300	371	71
andesite		371	415	44
andesite (Broken)		415	433	18
andesite		433	555	122
Broken andesite	✓ ✓✓	555	575	20
fractured	✓ ✓✓	575	586	11
Med. hard rock w/ thin fishers		586	602	16

Date started May 19, 1986
Date completed June 16, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3400	80	294	72

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 602 feet
Casing record
Weight per foot 22.36 Thickness .250

Diameter	From	To
inches	feet	feet
8⅝ Od inches	0 feet	522 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type sand & cement grout
Depth of seal 104 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 104 feet to 602 feet

Perforations:
Type perforation factory sawed
Size perforation 1/8 x 3" x 3 row (triple)
From ..... feet to ..... feet
From 522 feet to 602 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 46 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature 63 °F. Quality good.

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons Well Drilling (Contractor)
Address 22 So Patterson, Sparks, Nev. (Contractor)
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957 (Actual Driller)
Signed Paul E. Williams Sr. (Contractor)
Date 6-27-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434