



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2174

1. OWNER William Paulson ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T. 21 S N/S R. 54 E County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources Parcel No. 16 Subdivision Name Boy Hollow Sub Div.

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	49	49
Clay	+	49	53	4
Clay		53	78	25
Clay	x	78	80	2
White clay with decomposed clay		80	138	58
Sandy clay		138	160	22

8. WELL CONSTRUCTION  
 Diameter hole 12 1/4 inches Total depth 160 feet  
 Casing record 8 5/8 x 160  
 Weight per foot 14.11 Thickness 15.6  
 Diameter From To  
8 5/8 inches 0 feet 160 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 160 feet  
 Perforations:  
 Type perforation Torch  
 Size perforation 1/8 x 6 2 Rows  
 From 120 feet to 160 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 NOV 26 1985  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 10-10-85  
 Date completed 10-13-85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 40 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Custom Drilling Contractor  
 Address 4425 Stacey Ave Contractor  
 Nevada contractor's license number 19219  
 Nevada contractor's drillers number 1081  
 Nevada driller's license number 1081 Actual Driller  
 Signed L.B. Beppert Contractor  
 Date 10-15-85

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours