WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27488
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2447

1. OWNER Toedette Poe
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 21S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) Parcel No. Lot. 2 Bed Rock (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Clay | | 0. | 6 | 6. |
| Clay | | 6. | 35 | 25 |
| Caliche | | 35 | 38 | 3 |
| Clay | | 38. | 46 | 8 |
| Caliche | WB. | 46. | 53 | 7 |
| Clay | | 53. | 76 | 21. |
| Caliche | WB. | 76 | 87 | 11. |
| Clay | | 87. | 120. | 33 |
| Caliche | WB | 120. | 128 | 8. |
| Clay | | 128. | 135 | 7 |
| Caliche | WB. | 135 | 148 | 13. |
| Clay | | 148 | 160. | 12 |

RECEIVED
MAY 5 1986
Div. of Water Resources
Branch Office · Las Vegas, NV.

Date started 5-2, 19 86
Date completed 5-2, 19 86

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 160 feet
Casing record 160 Ft. 8 5/8.
Weight per foot 14.11 Thickness .156

| Diameter | From | To |
|---|---|---|
| 8 5/8 inches | -1 feet | 160. feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch
Size perforation ⅛ inch by 6 inch
From 120 feet to 160. feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40. feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool. ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Custom Drilling (Contractor)
Address 4425 Stacey Ave (Contractor)
Nevada contractor's license number 19219
Nevada driller's license number 1081
Nevada driller's license number 1426 (Actual Driller)
Signed [signature] (Contractor)
Date 5-4-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434