WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 27512
Permit No.
Basin 212

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

in Book

NOTICE OF INTENT NO. 156

1. OWNER Gordon Martines
MAILING ADDRESS 1600 Arville, Las Vegas Nevada

ADDRESS AT WELL LOCATION Corner of Ford & Procyon
E½ NE¼ NW¼ SW¼ SW¼ 17 22 61

2. LOCATION SW ¼ SW ¼ Sec. 17 T. 22 N/S R. 61 E Clark County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
cemented gravel		0	220	220
cemented gravel	xx	220	230	10
cemented gravel		230	265	35
ggravel & sand		265	294	29
boulders		294	310	6
cemented gravel	xxx	310	350	40

RECEIVED
MAY 27 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 3-17-86, 19____
Date completed 4-10-86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailed 50	G.P.M. from 236 ft.		

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 10 inches Total depth 350 feet
Casing record 8 5/8 inch to 350 ft.
Weight per foot .156 Wall Thickness ____

Diameter	From	To
12" Hole inches	0 feet	50 feet
10" Hole inches	50 feet	350 feet
inches	feet	feet
8 5/8 inch inches Casing	0 feet	350 feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation torch cut
Size perforation 3/16" X 10"
From 210 feet to 350 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 210 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ ° F. Quality ____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name S. R. McKinney & Sons, Inc. (Contractor)
Address 1042 S. Main St. Las Vegas, Nevada (Contractor)
Nevada contractor's license number 2065
Nevada contractor's drillers number 45
Nevada driller's license number 270 (Actual Driller)
Signed [signature] (Contractor)
Date 5-22-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434