WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27514
Permit No.
Basin 212

In Book

NOTICE OF INTENT NO. 15 61

PRINT OR TYPE ONLY

1. OWNER Roberta Bartlett
MAILING ADDRESS 5786 Rainbow
Las Vegas, Nevada

ADDRESS AT WELL LOCATION Same

2. LOCATION SW NW ¼ SW ¼ Sec. 26 T. 19 N/S R. 60 E Clark County

PERMIT NO. ____ Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☒ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Deepening job from 200 to 300 ft.				
gravel, caving		200	205	5
graveley clay		205	220	15
gravel, caving		220	240	20
brown clay		240	255	15
gravel	xx	255	258	3
clay		258	275	17
gravel	xx	275	280	5
clay		280	290	10
gravel	xx	290	300	10

RECEIVED
MAY 27 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 6-19-85, 19____
Date completed 6-26-85, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Bailed	30 G.P.M.	from 170 ft.	

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 8 5/8 inches Total depth 200 feet
Casing record Now total depth 300 ft.
Weight per foot ____ Thickness ____

Diameter	From	To
8 5/8 inches	0 feet	200 feet
6 5/8 inches	195 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type ____
Depth of seal ____ feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation torch
Size perforation 3/16" X 10"
From 200 to feet to 300 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 155 feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ ° F. Quality ____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name S. R. McKinney & Sons, Inc. (Contractor)
Address 1042 S. Main St. Las Vegas, Nevada (Contractor)
Nevada contractor's license number 2065
Nevada contractor's drillers number 45
Nevada driller's license number 45 270 (Actual Driller)
Signed [signature] (Contractor)
Date 7-26-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434