


Log No. 27516  
 Permit No. \_\_\_\_\_  
 Basin 162



**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2220

PRINT OR TYPE ONLY

1. OWNER David VanHeusen ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump, Nevada 89041

2. LOCATION SE 1/4 SW 1/4 Sec. 8 T. 20-S N/S R. 53 E Nye County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Light Brown Clay		4	25	21
Soft Brown Clay		25	46	21
Tough Brown Clay		46	56	10
Soft Brown Clay	x	56	88	32
Brown Clay	x	88	140	52

**RECEIVED**

MAY 30 1986

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started March 20, 1986  
 Date completed March 20, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. 20 gals. Draw down 4 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

8. WELL CONSTRUCTION

Diameter hole 8 inches Total depth 140 feet  
 Casing record 140 ft. of 8 in. casing  
 Weight per foot 15 lbs. Thickness .156  

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>140</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 140 feet

Perforations:

Type perforation Torch Cut  
 Size perforation 1/4 in. width 8 in. long  
 From 80 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level 37 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Contractor

Address St. Rt. Box 36525 Contractor

Nevada contractor's license number 7484

Nevada contractor's drillers number \_\_\_\_\_

Nevada driller's license number 725 Actual Driller

Signed Charles Nyberg Contractor

Date May 26, 1986