WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLERS REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 27518
Permit No.
Basin 162

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2222

1. OWNER Gene & Lee Ray
MAILING ADDRESS Pahrump, Nevada 89041
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SW ¼ Sec. 9 T. 20-S N/S R. 53 E Nye County
PERMIT NO. (Issued by Water Resources) | Parcel No. 91 | Subdivision Name Unit D Cal-Vegas Ranches

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Soft Brown Clay | | 4 | 40 | 36 |
| Tough Brown Clay | | 40 | 48 | 8 |
| Soft Snady Clay | x | 48 | 80 | 32 |
| Chalky White Clay | x | 80 | 115 | 35 |
| Brown Clay | x | 115 | 140 | 25 |

RECEIVED
MAY 30 1986
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 26, 1986
Date completed March 26, 1986

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | | | |

BAILER TEST
G.P.M. 20 gals. Draw down 4 feet ¼ hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 140 feet
Casing record 140 ft. of 8 in. casing
Weight per foot 15 lbs. Thickness .156

| Diameter | From | To |
|---|---|---|
| 8 inches | 0 feet | 140 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation Torch Cut
Size perforation ¼ in width 8 in. long
From 80 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address St. Rt. Box 36525 (Contractor)
Nevada contractor's license number 7484
Nevada contractor's drillers number
Nevada driller's license number 725 (Actual Driller)
Signed Charles Nyberg (Contractor)
Date May 26, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434