

1/2

WELL DRILLERS REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

pg #1 of 2 pages
 NOTICE OF INTENT NO. 7683

1. OWNER RAYMOND & GERDA HEMENWAY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 4684 700 Wild Horse same
Reno, NV 89510
 2. LOCATION SE 1/4 SE 1/4 Sec. 14 T 22 N/S R. 21 E Washoe County
 PERMIT NO. 51170 67A-126-21 Palomino Valley Unit 14-2-1-11 part 2
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	1	1
Light brown sand stone		1	38	37
Light green sand stone		38	56	18
Dark brown sand stone		56	90	34
Light brown andasite		90	178	88
Soft reddish brown volcanic rock		178	222	44
Light brown volcanic rock w/ little quartz		222	310	99
Reddish brown volcanic rock		310	341	31
Brown volcanic rock		341	406	65
Soft volcanic rock w/ brown clay streaks		406	416	10
Brown volcanic rock		416	440	24
Brown clay		440	451	11
Brown volcanic rock		451	520	69
Hard brown volcanic rock		520	530	10
Small fracture	X	531	531	0
Hard brown volcanic rock		531	535	4
Fracture	X	535	537	2

continued on pg 2

Date started 7-10-86, 19_____
 Date completed 7-14-86, 19_____
 7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 625 feet
 Casing record 625
 Weight per foot _____ Thickness .156
 Diameter From To
6 5/8 inches 0 feet 625 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 625 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6" around
 From 525 feet to 605 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 200 feet below land surface
 Flow 20 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370 Reno, NV 89510
 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923
 Actual Driller
 Signed Wayne Drilling, Inc.
 Contractor
 Date July 16, 1986

