


Log No. 27541

Permit No. _____

Basin 6-91 Truckee Canyon



WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7685.....

PRINT OR TYPE ONLY

1. OWNER CRAIG CURTIS ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 18253 70 Night Owl
Reno, NV 89511 Reno, NV
 2. LOCATION NW 1/4 NW 1/4 Sec 14 T 19 N/S R 18 E Washoe County
 PERMIT NO. _____ Mogul Subdivision Name _____
 Issued by Water Resources _____ Parcel No. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------|--------------|------|-----|------------|
| Top soil | | 0 | 1 | 1 |
| Brown clay | | 1 | 26 | 25 |
| Dark brown clay | | 26 | 33 | 7 |
| Gray clay | | 33 | 73 | 40 |
| Soft zone | X | 73 | 74 | 1 |
| Gray clay | | 74 | 93 | 19 |
| Soft zone | X | 93 | 94 | 1 |
| Gray clay | | 94 | 105 | 11 |
| Soft zone | X | 105 | 107 | 2 |
| Gray clay | | 107 | 135 | 28 |
| Soft zone | | 135 | 136 | 1 |
| Gray clay | | 136 | 145 | 9 |
| Soft zone | | 145 | 146 | 1 |
| Gray clay | | 146 | 167 | 21 |
| Soft zone | X | 167 | 168 | 1 |
| Gray clay | | 168 | 203 | 35 |
| Soft zone | | 203 | 210 | 7 |
| Gray clay | | 210 | 218 | 8 |
| Soft zone | X | 218 | 223 | 5 |
| Gray clay | | 223 | 239 | 16 |
| Gray, brown clay | | 239 | 241 | 2 |
| Gray clay | | 241 | 275 | 34 |

8. WELL CONSTRUCTION
 Diameter hole 10 x 6 inches Total depth 275 feet
 Casing record 275
 Weight per foot _____ Thickness 156
 Diameter From To
6 5/8 inches 0 feet 275 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type cement
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 275 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6" around
 From 105 feet to 175 feet
 From 215 feet to 235 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 44 feet below land surface
 Flow 15 G.P.M. _____ P.S.I.
 Water temperature cold ° F. Quality clear

Date started 7-15-86, 19_____
 Date completed 7-16-86, 19_____
 7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |
| | | | |

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370 Reno, NV 89510 Contractor
 Nevada contractor's license number 22549
 Nevada contractor's drillers number 908
 Nevada driller's license number 923 Actual Driller
 Signed Jerry C. Hedman Contractor
 Date July 21, 1986

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours