WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27542
Permit No.
Basin G-87 Truckee Meadows

PRINT OR TYPE ONLY

pg. 1 of 2 pages
NOTICE OF INTENT NO. 6846

1. OWNER DR. & MRS. PRUPAS/ALTMAN CONSTRUCTION
MAILING ADDRESS 457 Court St.
Reno, NV 89501
ADDRESS AT WELL LOCATION 770 Kevin Cir.
Reno, NV

2. LOCATION SW ¼ NE ¼ Sec. 2 T. ~~19~~ 18 N/S R. 19 E Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. SW Reno (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Air/Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dark brown clay		0	3	3
Brown sandy clay w/ small gravels		3	30	27
Soft brown sandy clay w/ gravels		30	62	32
Brown clay		62	73	11
Soft brown clay w/ 40 % gravels		73	94	21
Brown volcanic rock		94	121	27
Soft zone	X	121	124	3
Brown volcanic rock		124	144	20
Fractured rock		144	146	2
Brown volcanic rock		146	157	11
Soft zone	X	157	168	11
Brown volcanic rock		168	169	1
Clay streaks		169	170	1
Brown volcanic rock		170	186	16
Soft zone		186	188	2
Brown volcanic rock		188	191	3
Soft Med. volcanic rock		191	194	3
Brown volcanic rock		194	200	6
Soft zone		200	206	6
Red clay		206	213	7
Very hard volcanic rock		213	223	10

(continued page 2)

Date started 7-17-86, 19
Date completed 7-22-86, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 10x 6 inches Total depth 240 feet
Casing record 240
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	240 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 51 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 51 feet to 240 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6" around
From 100 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 8 feet below land surface
Flow 12 G.P.M. P.S.I.
Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 Reno, NV 89510 (Contractor)
Nevada contractor's license number 22549
Nevada contractor's drillers number 908
Nevada driller's license number 923
Signed Ingrid Hadman / GCH (Actual Driller / Contractor)
Date July 25, 1986

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27542
Permit No.
Basin

PRINT OR TYPE ONLY

pg. 2 of 2 pages
NOTICE OF INTENT NO. 6846

1. OWNER DR. & MRS PRUPAS/ALTMAN CONSTRUCTION ADDRESS AT WELL LOCATION
MAILING ADDRESS

2. LOCATION ¼ ¼ Sec. 02 T. 18 N/S R. 19 E County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soft zone (has red streaks)		223	226	3
Volcanic rock		226	240	14

Date started ..., 19
Date completed ..., 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole inches Total depth feet
Casing record
Weight per foot Thickness

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name
Contractor
Address
Contractor
Nevada contractor's license number
Nevada contractor's drillers number
Nevada driller's license number
Actual Driller
Signed Ingrid Hedman / GCH
Contractor
Date 7-25-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434