WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27549
Permit No.
Basin 8-102 Churchill V.

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 3856

1. OWNER BENNY JOE RATCLIFF
MAILING ADDRESS 7615 WINCHESTER
SILVER SPRINGS NV. 8
ADDRESS AT WELL LOCATION SAME AS MAILING

2. LOCATION NE ¼ SE ¼ Sec. 18 T. 17 ☒S R. 25 E. Lyon County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FINE SAND		0	8	8
COURSE SAND		8	25	17
CLAY + SAND		25	29	4
COURSE SAND		29	45	16
COURSE SAND + COBBLE STONES		45	50	10
COURSE SAND		50	60	10
COURSE SAND + COBBLE STONES		60	65	5
BLUE CLAY + COURSE SAND		65	67	2
COURSE SAND		67	95	28
COURSE SAND, GRAVEL + CLAY		95	102	7
COURSE SAND + CLAY		102	118	16
COURSE SAND		118	120	2
COURSE SAND + COBBLE STONES	Y	120	140	20

Date started 5-22, 1986
Date completed 5-30, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3450	40	4'6	3 HR.

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 12 5/8 inches Total depth 141 feet
Casing record
Weight per foot Thickness .156

Diameter	From	To
8 5/8 inches	(+) 1 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type GROUT
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 140 feet

Perforations:
Type perforation SAWED
Size perforation 3/32" X 3" X 8 ROWS
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 35' 6" feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature COLD° F. Quality GOOD

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name OGDEN BROS DRILLING (Contractor)
Address 162 N. BYBEE LN. YERINGTON, NV. (Contractor)
Nevada contractor's license number 15646
Nevada contractor's drillers number 870 + 530
Nevada driller's license number 870 (Actual Driller)
Signed [signature] (Contractor)
Date 6-16-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434