

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 1712

1. OWNER Nelson White ADDRESS AT WELL LOCATION Artist View, Wellington, Nevada 89444  
 MAILING ADDRESS Wellington, Nevada 89444  
 2. LOCATION SW 1/4 NE 1/4 Sec. 13 T. 11 N. R. 23 E. Lyon County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy loam } topsoil }	No	0	8	8
Gravel and } sand }	No	8	20	12
Yellow sandy } clay }	No	20	56	36
Sand	Yes	56	72	12
Large gravel	Yes	72	85	13
Sand		85	96	11

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 96 feet  
 Casing record 96  
 Weight per foot \_\_\_\_\_ Thickness 250  
 Diameter \_\_\_\_\_ From \_\_\_\_\_ To \_\_\_\_\_  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type \_\_\_\_\_  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation SAW SLOT  
 Size perforation 2 1/2" x 3/32"  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 53 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold ° F. Quality Good

Date started 6-27- 1986  
 Date completed 7-3- 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1 Hsp.</u>	<u>25</u>	<u>5 ft.</u>	<u>12</u>

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Contractor  
 Address Box 92, Artist View, Nevada 89430  
 Nevada contractor's license number 12272  
 Nevada contractor's drillers number 718  
 Nevada driller's license number 718  
 Signed Edmund Miller Actual Driller Contractor  
 Date \_\_\_\_\_

BAILER TEST  
 G.P.M. 30 Draw down 5 feet 5 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours