WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 27568
Permit No.
Basin 6-87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 5794

1. OWNER Parkwood Homeowners Association
MAILING ADDRESS 412 Lorraine St. Reno Nv 89509
ADDRESS AT WELL LOCATION Millbrook + Octillio Reno Nv.

2. LOCATION SE ¼ NW ¼ Sec. 25 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) Parcel No. Parkwood (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders - sd - gravel		0	20	
Sd - gravel		20	40	
Clay		40	59	
Sd + gravel		59	73	
Boulders		73	80	
Sd + gravel		80	105	
Boulders - gravel - clay		105	108	
Sd - gravel		108	120	
Crse sd		120	130	
Clay		130	145	
gravel		145	156	
Clay		156	158	
Sd + gravel		158	160	
Sticky clay		160	164	
Rock (SS)		164	166	
green clay		166	172	
SS		172	176	
Sd		176	226	
Clay		226	229	
Mostly Sd - some clay stringers not over 1' Thick		229	300	

Date started 7-14, 1986
Date completed 7-23, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12¼ inches Total depth 300 feet
Casing record 8" 0 - 250
Weight per foot Thickness .188

Diameter	From	To
12¼ inches	0 feet	250 feet
5⅝ inches	250 feet	300 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 172 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 210 feet to 250 feet

Perforations:
Type perforation slotted
Size perforation ⅛
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 26' feet below land surface
Flow 400 G.P.M. P.S.I.
Water temperature 110 ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Woytek Drilling Co (Contractor)
Address 4662 Maynard Way Sparks, Nv. (Contractor)
Nevada contractor's license number 09157
Nevada contractor's drillers number 1374
Nevada driller's license number 1442 (Actual Driller)
Signed Les Woytek (Contractor)
Date 7-24-86

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434