



**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 2701

PRINT OR TYPE ONLY

1. OWNER Leonard B. Romero ADDRESS AT WELL LOCATION North  
 MAILING ADDRESS 2627 So. Lamb Blvd, Sp 50 Caliente NV 89008  
Las Vegas, NV 89120  
 2. LOCATION SE 1/4 NE 1/4 Sec. 14 T. 3.5 N/S R. 6.7 E Lincoln County  
 PERMIT NO. \_\_\_\_\_ Nevada 89008  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Top Soil, Sand</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>Red Clay</u>		<u>8</u>	<u>85</u>	<u>77</u>
<u>gravel</u>		<u>85</u>	<u>95</u>	<u>10</u>
<u>Red clay</u>		<u>95</u>	<u>110</u>	<u>15</u>
<u>gravel</u>		<u>110</u>	<u>115</u>	<u>5</u>
<u>Layers of clay gravel</u>		<u>115</u>	<u>165</u>	<u>50</u>
<u>Red Clay</u>		<u>165</u>	<u>169</u>	<u>3</u>

8. 12" x 50' WELL CONSTRUCTION  
 Diameter hole 8" x 11 1/2" inches Total depth 168 feet  
 Casing record 8" x 169'  
 Weight per foot \_\_\_\_\_ Thickness 1/4"  

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 5.0' feet  
 Gravel packed: Yes  No   
 Gravel packed from 5.0 feet to 100 feet  
 Perforations:  
 Type perforation Torch  
 Size perforation 1/4 x 12  
 From 100 feet to 169 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**

JUL 8 1986  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started June 26 1986  
 Date completed July 3 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL  
 Static water level 69 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Darrell H. Free Contractor  
 Address Box 122 Pahrump NV 89042 Contractor  
 Nevada contractor's license number 3422  
 Nevada contractor's drillers number 30  
 Nevada driller's license number 1441 Actual Driller  
 Signed Darrell H. Free Contractor  
 Date July 5, 1986

BAILER TEST  
 G.P.M. 10 Draw down not measurable feet 2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours