



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2352

1. OWNER Service Plumbing Corp. ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3050 West Wood Las Vegas Nevada 89109

2. LOCATION SE 1/4 NE 1/4 Sec. 28 T. 19 S. N/S R. 53 E. Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Lot 15 Block 6 Unit 3 Bell Vista Subdivision  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	15	15
Grey Clay		15	62	47
Clay with Gravel		62	86	24
Brown Clay	x	86	108	22
Shale		108	114	4
Soft Brown Clay	x	114	150	36
Hard Shale		150	158	8
Soft Brown Clay	x	158	186	28
Light Brown Clay	x	186	200	14

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 200 feet  
 Casing record 200ft. of 8 in. casing  
 Weight per foot 15 lbs. Thickness .156

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 200 feet

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/2 in width 8 in long  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**  
 SEP 8 1986  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started August 22, 1986  
 Date completed August 22, 1986

9. WATER LEVEL  
 Static water level 74 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ ° F. Quality \_\_\_\_\_

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address ST. RT. BOX 36525 Contractor  
 Nevada contractor's license number 7484  
 Nevada contractor's drillers number \_\_\_\_\_  
 Nevada driller's license number 725 Actual Driller

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 gals. Draw down 4 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

Signed Charles Nyberg Contractor  
 Date Sept. 3, 1986