

OFFICE USE ONLY  
 Log No. 27689  
 Permit No. \_\_\_\_\_  
 Basin 7-92(A) Lehman V. West

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7391

1. OWNER Dorsey & Cindy Murphy ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3845 Joy Lane 10705 Wells Fargo Rd  
Reno, Nv 89512 Lot 30  
 2. LOCATION 2 1/4 NE 1/4 Sec. 26 T 21 N/S R. 18 E Washoe County \_\_\_\_\_  
 PERMIT NO. 87-363-16 Silver Knolls Ranch Estates-Unit # 5  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

| Material        | Water Strata | From | To  | Thick-ness |
|-----------------|--------------|------|-----|------------|
| Brown clay      |              | 0    | 3   | 3          |
| Green clay      |              | 3    | 114 | 111        |
| dark green clay |              | 114  | 154 | 40         |
| lite brown clay |              | 154  | 171 | 17         |
| gray black clay |              | 171  | 197 | 26         |
| T.D. 197        |              |      |     |            |

8. 10"-58" WELL CONSTRUCTION  
 Diameter hole 8 1/2 inches Total depth 197 feet  
 Casing record 6 5/8"  
 Weight per foot 10.78 & 12.92 Thickness .156 & .188  
 Diameter From To  
6 5/8 inches +3' feet 197 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 197 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 177 feet to 197 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 8/14/86, 19\_\_\_\_\_  
 Date completed 8/14/86, 19\_\_\_\_\_

7. WELL TEST DATA

| Pump RPM                                 | G.P.M. | Draw Down | After Hours Pump |
|--|--------|-----------|------------------|
| Blew well with air to clean and develop. |        |           |                  |
|  |        |           |                  |
|  |        |           |                  |

9. WATER LEVEL  
 Static water level 120 feet below land surface  
 Flow 20+ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date 8/14/86

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours