

OFFICE USE ONLY
 Log No. 27703
 Permit No. 187
 Basin 187

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER G & P Construction ADDRESS W. Star Valley, Nevada

2. LOCATION SE 1/4, SE 1/4 Sec 12 T. 36 N/S R. 66 E E1K6 County
 PERMIT NO. Waver C-51

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Tan Sandy Clay & Gravel		0	10.2	10.2
Tan Clay		10.2	11.5	1.3
Gravel & Clay	X	11.5	16.4	5.1
Cemented Gravel	X	16.4	17.6	1.2
Clay & Gravel	X	17.6	31.0	13.4

8. WELL CONSTRUCTION
 Diameter hole 6 inches Total depth 31.0 feet
 Casing record.....
 Weight per foot..... Thickness.....

Diameter	From	To
<u>6</u> inches	<u>1</u> feet	<u>30.6</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type.....
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from..... feet to..... feet

Perforations:
 Type perforation 3 Knife
 Size perforation 3/16 X 3"
 From 12.5 feet to 27.5 feet
 From..... feet to..... feet
 From..... feet to..... feet
 From..... feet to..... feet

Date started 7/30/86, 1986
 Date completed 7/31/86, 1986

9. WATER LEVEL
 Static water level 8.4 Feet below land surface.....
 Flow..... G.P.M.
 Water temperature..... ° F. Quality.....

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elsing Drilling & Pump Inc.
 Address P.O. Box 919, Twin Falls, Idaho 83301
 Nevada contractor's license number 0017177
 Nevada driller's license number 1295
 Signed Arnold Elsing
 Date Aug 8, 1986

BAILER TEST

G.P.M.	Draw down	feet	hours