

OFFICE USE ONLY
 Log No. 27711
 Permit No. _____
 Basin 8-105 Carson

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7135

PRINT OR TYPE ONLY

1. OWNER Joe Shultz ADDRESS AT WELL LOCATION 2666 Billy's Rd
Gardnerville NV Minden NV
 MAILING ADDRESS Box 1493
 2. LOCATION $\frac{1}{4}$ Sec 31 T. 14 N/S R. 20 E Douglas County
 PERMIT NO. _____ Issued by Water Resources _____ Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay</u>		<u>0</u>	<u>3</u>	
<u>Clay & SAND</u>		<u>3</u>	<u>7</u>	
<u>SAND</u>		<u>7</u>	<u>15</u>	
<u>Clay & SAND</u>		<u>15</u>	<u>47</u>	
<u>Gravel</u>		<u>47</u>	<u>80</u>	
<u>Clay & SAND</u>		<u>80</u>	<u>83</u>	

8. WELL CONSTRUCTION
 Diameter hole 8 5/8 inches Total depth 83 feet
 Casing record _____
 Weight per foot _____ Thickness .250
 Diameter From To
12 inches 0 feet 50 feet
8 5/8 inches 50 feet 83 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type Cement grout
 Depth of seal 50' feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation Factory
 Size perforation 3 x 7/32
 From 60 feet to 80 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 6 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold ° F. Quality _____

Date started 8-11, 1986
 Date completed 8-18, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawchack Drilling, Inc. Contractor
 Address Box 536 Gardnerville, NV. Contractor
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 1380
 Nevada driller's license number 1425
 Signed Eddy Kawchack Actual Driller
 Date 8/9/86 Contractor

BAILER TEST
 G.P.M. 20 Draw down 15 feet 2 1/2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours