

OFFICE USE ONLY  
 Log No. 27714  
 Permit No. \_\_\_\_\_  
 Basin 84

T

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 7483

PRINT OR TYPE ONLY

1. OWNER James Huyvaert ADDRESS AT WELL LOCATION Bacon Rind Rd  
 MAILING ADDRESS P. O. Box 5782 Palomino Valley  
Sparks, Nv 89432

2. LOCATION NE 1/4 NE 1/4 Sec 1 T 21 N/S R 20 E Washoe County  
 PERMIT NO. 76-280-01  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  air

6. LITHOLOGIC LOG

| Material   | Water Strata | From | To  | Thick-ness |
|--|--------------|------|-----|------------|
| Loose D. G. sands  |              | 0    | 11  | 11         |
| firm D.G. with clay mix  |              | 11   | 165 | 154        |
| Hard blue and black rock with traces of purple   |              | 165  | 210 | 45         |
| Hard black & gray rock very fractured with small amount of pyrite and quartz and some purple |              | 210  | 331 | 121        |
| T.D. 331   |              |      |     |            |

*See log # 66907 for Deepening*

8. 10"-50" WELL CONSTRUCTION  
 Diameter hole 8" inches Total depth 331 feet  
 Casing record 6 5/8" & 5"  
 Weight per foot 10.78 Thickness 156 & .188

| Diameter            | From            | To              |
|---------------------|-----------------|-----------------|
| <u>6 5/8</u> inches | <u>+2</u> feet  | <u>295</u> feet |
| <u>5"</u> inches    | <u>291</u> feet | <u>331</u> feet |
| _____ inches        | _____ feet      | _____ feet      |
| _____ inches        | _____ feet      | _____ feet      |
| _____ inches        | _____ feet      | _____ feet      |
| _____ inches        | _____ feet      | _____ feet      |

Surface seal: Yes  No  Type grout  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 295 feet

Perforations:  
 Type perforation factory  
 Size perforation 3/32 X 3  
 From 275 feet to 295 feet  
 From 311 feet to 331 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 190 feet below land surface  
 Flow 20 G.P.M. P.S.I.  
 Water temperature cool F. Quality good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Aqua Drilling and Well Service, Inc.  
 Contractor  
 Address 2255 Glendale Ave. Sparks, Nv 89431  
 Contractor  
 Nevada contractor's license number 15291  
 Nevada contractor's drillers number 1132  
 Nevada driller's license number 1132  
 Actual Driller  
 Signed Roger M. Thrall  
 Roger M. Thrall Contractor  
 Date 8/15/86

7. WELL TEST DATA

| Pump RPM                                 | G.P.M. | Draw Down | After Hours Pump |
|--|--------|-----------|------------------|
|  |        |           |                  |
| Blew well with air to clean and develop. |        |           |                  |
|  |        |           |                  |

BAILER TEST

| G.P.M. | Draw down | feet | hours |
|--------|-----------|------|-------|
|        |           |      |       |
|        |           |      |       |
|        |           |      |       |