

**WELL DRILLERS REPORT**

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7718

1. OWNER KEN BOWIE ADDRESS AT WELL LOCATION 6574 ROBERSON LANE FALLON, NEVADA  
 MAILING ADDRESS 6534 ROBERSON LANE FALLON, NEVADA 89406  
 2. LOCATION NW 1/4 NE 1/4 Sec. 19 T. 19 N/S R. 23 E. Church. 11 County \_\_\_\_\_  
 PERMIT NO. 08-131-95 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	9'	9'
CLAY		9'	11'	2'
SAND		11'	13'	2'
CLAY		13'	24'	11'
COARSE SAND	WATER	24'	39'	15'
CLAY		39'		

8. WELL CONSTRUCTION  
 Diameter hole 8 inches Total depth 39 feet  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 15.6  

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>25</u> feet
<u>8</u> inches	<u>0</u> feet	<u>39</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type CEMENT  
 Depth of seal 25 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Perforations:  
 Type perforation MACHINED  
 Size perforation 2 3/16 x 3"  
 From 25 feet to 39 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 11 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name VERNON CANNON JR Contractor  
 Address 1370 ROBERSON LN FALLON, NV Contractor  
 Nevada contractor's license number 23317  
 Nevada contractor's drillers number 1455  
 Nevada driller's license number 1455 Actual Driller  
 Signed Vernon Cannon Jr Contractor  
 Date Sept 2, 1986

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3450</u>	<u>24</u>	<u>5 1/2</u>	<u>4</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____