

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1480

PRINT OR TYPE ONLY

1. OWNER Devin Patrick ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 6530 Lotus St. 6010 Goldenrod
Reno, Nv 89506

2. LOCATION NW 1/4 NW 1/4 Sec. 2 T 17 N/S R. 19 E Washoe County Washoe
 PERMIT NO. 045-543-01 — Galena Terrace Estates # 2
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
granite sand and boulders		0	315	315
T.D. 298				

Plugged by well log 12/1009

8. 10"- 70' WELL CONSTRUCTION
 Diameter hole 8 inches Total depth 298 feet
 Casing record 6 5/8"
 Weight per foot 10.78 - 12.92 Thickness .156 - .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>298</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout
 Depth of seal 70 feet
 Gravel packed: Yes No
 Gravel packed from 70 feet to 298 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 278 feet to 298 feet
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 150 feet below land surface
 Flow 25+ G.P.M. P.S.I. _____
 Water temperature cold °F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
Contractor
 Address 2255 Glendale Ave. Sparks, Nv 89431
Contractor
 Nevada contractor's license number 15291
 Nevada contractor's drillers number 1132
 Nevada driller's license number 1132
Actual Driller
 Signed Roger M Thrall
 Roger M Thrall Contractor
 Date 8/26/86

Date started 8/25/86, 19____
 Date completed 8/25/86, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well for 1 hour to clean and develop.			

BAILER TEST

G.P.M.	Draw down	feet	hours